



AHMEDABAD MUNICIPAL CORPORATION  
AHMEDABAD FIRE AND EMERGENCY SERVICES DEPARTMENT  
Danapith Fire Station (Hqrs.) Nr. AM Corporation, Danapith Ahmedabad-380001.  
Phone No: 079 22148466/67/68 Fax No:079 22148598

F.B.No. 23, School NOC

14<sup>th</sup> February 2020

NO OBJECTION CERTIFICATE

This is to certify that the management of "UDGAM SCHOOL FOR CHILDREN." Located at, T.P.-2 (Thaltej), F.P.No. 6 (R.S.No.29.30.47/p), Survey No. 47/29/30, Opp. Sardar Patel Institute, Thaltej, Ahmedabad. Have provided for the required fire Protection of the Institute Building and was inspected today and fire risks observed were of very low category Gr. + 5 Floor and evacuation in case of emergency cannot be a problem.

The Fire Service Department has NO OBJECTION as below mentioned installation is Complete.

• Fire Pump	(01 Nos.)
• 350 mtrs 4 & 6 Pipeline Network	(370 mtr.)
• Hose Reel Drum with Hose Reel	(15 Nos.)
• Hydrant Point	(17 Nos.)
• Optical Smoke Detector System installed.	(02 Sets)
• Fire Alarm installed.	
• Fire Inlet	
• MCP	(10 Nos.)
• 5 Kg. Capacity DCP Type Fire Extinguisher	(14 Nos.)
• 5 Kg. Capacity ABC Type Fire Extinguisher	(01 Nos.)
• 6 Kg. Capacity ABC Type Fire Extinguisher	(05 Nos.)
• 5 Kg. Capacity Automatic Modular ABC Type Fire Extinguisher	(02 Nos.)
• 4.5 Kg. Capacity Co2 Type Fire Extinguisher.	(14 Nos.)
• 2 Kg. Capacity Co2 Type Fire Extinguisher.	(07 Nos.)
• Autoglow Signages	(110 Nos.)

All the Fire equipments installed shall be maintained in working order throughout the validity period of this certificate.

The Certificate is valid till 28<sup>th</sup> February 2021

Chief Fire Officer  
Ahmedabad Municipal Corporation

