



**AHMEDABAD MUNICIPAL CORPORATION**  
**AHMEDABAD FIRE AND EMERGENCY SERVICES DEPARTMENT**  
Danapith Fire Station (Hqrs.) Nr. AM Corporation, Danapith Ahmedabad-380001.  
Phone No: 079 22148466/67/68 Fax No:079 22148598

**F.B.No. 027, School NOC**

**NO OBJECTION CERTIFICATE**

14<sup>th</sup> February 2020

This is to certify that the management of "UDGAM SCHOOL FOR CHILDREN." Located at, T.P.-2 (Thaltej), F.P.No. 6 (R.S.No.29.30,47/p), Survey No. 47/29/30, Opp. Sardar Patel Institute, Thaltej, Ahmedabad. Have provided for the required fire Protection of the Institute Building and was inspected today and fire risks observed were of very low category Gr. + 5 Floor and evacuation in case of emergency cannot be a problem.

The Fire Service Department has NO OBJECTION as below mentioned installation is Complete.

- Fire Pump (01 Nos.)
- 350 mtrs 4 & 6 Pipeline Network (370 mtr.)
- Hose Reel Drum with Hose Reel (15 Nos.)
- Hydrant Point (17 Nos.)
- Optical Smoke Detector System installed. (02 Sets)
- Fire Alarm installed.
- Fire Inlet
- MCP (10 Nos.)
- 5 Kg. Capacity DCP Type Fire Extinguisher (14 Nos.)
- 5 Kg. Capacity ABC Type Fire Extinguisher (01 Nos.)
- 6 Kg. Capacity ABC Type Fire Extinguisher (05 Nos.)
- 5 Kg. Capacity Automatic Modular ABC Type Fire Extinguisher (02 Nos.)
- 4.5 Kg. Capacity Co2 Type Fire Extinguisher (14 Nos.)
- 2 Kg. Capacity Co2 Type Fire Extinguisher (07 Nos.)
- Autoglow Signages (110 Nos.)

All the Fire equipments installed shall be maintained in working order throughout the validity period of this certificate.

The Certificate is valid till 28<sup>th</sup> February 2021

Chief Fire Officer  
Ahmedabad Municipal Corporation

