




AHMEDABAD MUNICIPAL CORPORATION
MAHANAGAR SEVA SADAN
CENTRAL LABORATORY
(An ISO 9001: 2015 Accredited Laboratory)



Lic No QAC/R91/4650

Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India.

E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438.

June 24, 2020.

To,
The Principal
Udgam School for Children's,
Opp. Sardar Patel Institute, Thaltej,
Ahmedabad.

Dear Sir,

We have analyzed your water samples collected on Dt. 15-06-2020 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	GF Cooler Water	O/H Tank Water
		As per IS-10500-2012			
(1)	(2)	(3)	(4)	(5)	(6)
A. Organoleptic and Physical Parameters					
1	Colour, Hazen units, Max	5	15	0.1	0.1
2	pH value	6.5-8.5	No relaxation	8.02	8.13
3	Turbidity, NTU, Max	1	5	0.1	0.1
4	Total dissolved solids, mg/l, Max	500	2000	238	1088
B. General Parameters					
1	Total hardness (as CaCO3), mg/l, Max	200	600	70	300
2	Calcium (as Ca), mg/l, Max	75	200	20	80
3	Magnesium (as Mg), mg/l, Max	30	100	4.88	24.4
4	Chloride (as Cl), mg/l, Max	250	1000	65	300
5	Sulphate (as SO4) mg/l, Max	200	400	18.2	76.4
6	Total alkalinity as calcium carbonate, mg/l, Max	200	600	100	400
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil	Nil
C. Bacteriological Quality of Drinking Water					
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detected	Not Detected
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detected	Not Detected

Remarks:

1. The Central Laboratory, AMC, has collected the samples.
2. The result contained in this report relate only to the sample material tested.
3. The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated

[Signature]
Dr. H. C. Mandalia
Scientist In-Charge

A.D. S. N. 6
07/01/2021
R. No. 114417
07/01/2021



જાણકારી નં: 2896
6/1/2021

Ahmedabad Municipal Corporation

No. 153

HEALTH DEPARTMENT

Date : 07/01/2021

Sanitary Convenience Certificate

A Certificate for Sanitary Convenience is issued to the Manager / Secretary / Organizer of the ^{School} Theatres / Theatre named "UDDAAN SCHOOL FOR CHILDREN" - Manager - Dhiman Choksi Situated at OPP. Sardar Patel Trust, Thaltej, Ahmedabad for the period of 12 months / Days i.e. from 01/01/2021 to 31/12/2021

"Issued Subject to NOC from other Concerned Departments"

Copy to :-

1. The manager/Secretary of the Theatre/Organizer (AMC)
2. The Commissioner of Police, Ahmedabad.

Dy. Health Officer
Ahmedabad Municipal Corporation
North West Zone (AMC)